



2600SEG118
STANDARD FOR EQUIPMENT LOCKOUT / TAGOUT

APPENDIX B

LOCKOUT / TAGOUT PROCEDURE FOR CONFINED SPACES

1. Confined spaces (except Non-permit Entry Spaces) will be isolated from all adjacent or connecting spaces, systems, or energy sources prior to entry
2. In the event that hot work is to be performed in or on a confined space, the space shall be isolated from any adjacent spaces or connected systems that may be adversely affected by, or might generate an explosive or toxic atmosphere as result of the hot work.
3. Isolation from energy sources involves physically blocking any actual or potential energy source from entering the confined space and will be performed in accordance with this Standard.
 - a. The use of additional procedures when the confined space is of double wall construction will be determined by the Competent Person and noted on the entry permit.
4. In continuous systems where complete isolation is not possible (sewers, utility tunnels, etc.), specific written procedures will be used to safeguard against hazards normally prevented by isolation.

Source: *Manual de Prácticas de Seguridad para Espacios Confinados de la ACP.*