



PANAMA CANAL AUTHORITY CHECKLIST

SAFETY AND ENVIRONMENTAL DEPARTMENT SAFETY DIVISION	SUBJECT: Ventilation Work Checklist	REVISION A	PAGE 1 OF 1
FOR USE WITH VENTILATION STANDARD 2600ESS-291	REVISION DATE June 20, 2006	EFFECTIVE DATE: June 20, 2006	

Area	Checklist	2600-ESS-291	Check (✓ or NA)
Work Environment	Confined Space Activity		6.2.1
	--Ventilation is available for the work being performed.		
	--The work generates contaminants.		
	--Is the ventilation adequate for this type of work?		
	--The contaminants generated are efficiently removed.		
	Shop Activity (Welding)		
	--Work in welding shop		
	--Is there local extraction ventilation?		6.2.3
	--Contaminants are discharged to areas where third parties are being affected.		6.2.3.2
	--The installed ventilation system is sufficient to collect the volume of contaminants generated.		6.2.3.1
	Shop Activity (Woodworking)		
	--Work in woodworking shop		
	--Is there local extraction ventilation?		6.2.2
	--The ventilation system is sufficient to collect the volume of contaminants generated.		6.2.2.1
	--The generated material (wood dust and sawdust) is collected for final disposal.		6.2.2.1
	Spray Painting in Booths		
--Extraction ventilation is used.		6.2.5	
--The average suction linear speed is of at least 100 cfm.		6.2.5	
General Work Practices	Sandblasting Operations in Enclosed Spaces		6.2.6
	--There is extraction ventilation.		
	--The extraction flow is of 500 - 2000 cfm.		
	--The generated material is collected for final disposal.		
	--The shop ventilation system is operational.		
	--System maintenance or repair records are kept.		7.0